

# Certificate of Compliance

**Certificate:** 1662790

**Master Contract:** 220331

**Project:** 1805798


**Date Issued:** June 21, 2006

**Issued to:** Mettler-Toledo GmbH  
Im Hackacker 15  
Urdorf, 8902  
SWITZERLAND


*The products listed below are eligible to bear the CSA Mark shown*



**Issued by:** Carole Lemay



**Authorized by:** H el ene Vaillancourt  
Operations Manager



## PRODUCTS

CLASS 2258 04 - PROCESS CONTROL EQUIPMENT - Intrinsically Safe Entity - For Hazardous Locations

Class I, Division 1, Groups A, B, C and D

Ex ib [ia] IIC

Transmitters Models 2100/2XH, 7100/2XH and Models 4100/2XH, input rated 30V, 4-20 mA, intrinsically safe devices provides intrinsically safe outputs to simple apparatus, ph, conductivity and oxygen probes when connected per control drawings 194.120-170, 194.220-190 and 194.320-190, 194.401-120. Maximum Ambient Temperature 55 C, Temperature Code T4.

For all models the input entity parameters are:

Terminals	Ui, Vmax	Ii, Imax	Pi, Pmax	Ci	Li
10, 11 or 14,15	30V	100mA	0.8W	32.4nF	0.24mH

Output entity parameters are:

2100/2XH

Terminals

**Certificate:** 1662790

**Master Contract:** 220331

**Project:** 1752689

**Date:** January 18, 2006

1/2, 4, 5, 6	Uo, Vsc	Io, Isc	Po	Co, Ca	Lo, La
IIC (gr A, B)	10V	10mA	25mW	3 $\mu$ F	250mH
IIB (gr. C)	10V	10mA	25mW	9 $\mu$ F	1H
IIC (gr. D)	10V	10mA	25mW	24 $\mu$ F	1H

**Terminals**

7, 8	Uo, Vsc	Io, Isc	Po	Co, Ca	Lo, La
IIC (gr A, B)	5V	3mA	4mW	100 $\mu$ F	1H
IIB (gr. C)	5V	3mA	4mW	300 $\mu$ F	1H
IIC (gr. D)	5V	3mA	4mW	800 $\mu$ F	1H

**Terminals**

17, 18, 19	Uo, Vsc	Io, Isc	Po	Co, Ca	Lo, La
IIC (gr A, B)	10V	14mA	35mW	3 $\mu$ F	170mH
IIB (gr. C)	10V	14mA	35mW	9 $\mu$ F	620mH
IIC (gr. D)	10V	14mA	35mW	24 $\mu$ F	1H

**Terminals**

Combined outputs	Uo, Vsc	Io, Isc	Po	Co, Ca	Lo, La
IIC (gr A, B)	10V	27mA	66mW	3 $\mu$ F	44mH
IIB (gr. C)	10V	27mA	66mW	9 $\mu$ F	180mH
IIC (gr. D)	10V	27mA	66mW	24 $\mu$ F	350mH

**Model 7100/2XH**

**Terminals**

1, 2, 3, 4, 5, 6	Uo, Vsc	Io, Isc	Po	Co, Ca	Lo, La
IIC (gr A, B)	10V	143mA	357mW	3 $\mu$ F	1.3mH
IIB (gr. C)	10V	143mA	357mW	9 $\mu$ F	5mH
IIC (gr. D)	10V	143mA	357mW	24 $\mu$ F	10mH

**Terminals**

7,8	Uo, Vsc	Io, Isc	Po	Co, Ca	Lo, La
IIC (gr A, B)	5V	3mA	4mW	100 $\mu$ F	1H
IIB (gr. C)	5V	3mA	4mW	300 $\mu$ F	1H
IIC (gr. D)	5V	3mA	4mW	800 $\mu$ F	1H

**Terminals**

Combined Outputs	Uo, Vsc	Io, Isc	Po	Co, Ca	Lo, La
IIC (gr A, B)	10V	146mA	365mW	3 $\mu$ F	1.3mH
IIB (gr. C)	10V	146mA	365mW	9 $\mu$ F	5mH
IIC (gr. D)	10V	146mA	365mW	24 $\mu$ F	10mH

**Model 7100/2XH**

**Terminals**

1, 2, 3, 4, 5, 6	Uo, Vsc	Io, Isc	Po	Co, Ca	Lo, La
------------------	---------	---------	----	--------	--------



Certificate: 1662790

Master Contract: 220331

Project: 1752689

Date: January 18, 2006

IIC (gr A, B)	9V	111mA	139mW	4µF	1.5mH
IIB (gr. C)	9V	111mA	139mW	12µF	6mH
IIC (gr. D)	9V	111mA	139mW	32µF	12mH

Terminals

7,8	Uo, Vsc	Io, Isc	Po	Co, Ca	Lo, La
IIC (gr A, B)	5V	3.5 mA	5mW	100µF	1H
IIB (gr. C)	5V	3.5 mA	5mW	300µF	1H
IIC (gr. D)	5V	3.5 mA	5mW	800µF	1H

Terminals

Combined Outputs	Uo, Vsc	Io, Isc	Po	Co, Ca	Lo, La
IIC (gr A, B)	9V	114.5mA	144mW	4µF	1.5mH
IIB (gr. C)	9V	114.5mA	144mW	12µF	6mH
IIC (gr. D)	9V	114.5mA	144mW	32µF	12mH

Model 4100/2XH

Terminals

1/2, 4, 5, 6	Uo, Vsc	Io, Isc	Po	Co, Ca	Lo, La
IIC (gr A, B)	10V	10mA	25mW	3µF	250mH
IIB (gr. C)	10V	10mA	25mW	9µF	1H
IIC (gr. D)	10V	10mA	25mW	24µF	1H

Terminals

7,8	Uo, Vsc	Io, Isc	Po	Co, Ca	Lo, La
IIC (gr A, B)	5V	1mA	2mW	100µF	1H
IIB (gr. C)	5V	1mA	2mW	300µF	1H
IIC (gr. D)	5V	1mA	2mW	800µF	1H

Terminals

Combined Outputs	Uo, Vsc	Io, Isc	Po	Co, Ca	Lo, La
IIC (gr A, B)	10V	11mA	28mW	3µF	250mH
IIB (gr. C)	10V	11mA	28mW	9µF	1H
IIC (gr. D)	10V	11mA	28mW	24µF	1H

CLASS 2258 03 - PROCESS CONTROL EQUIPMENT - Intrinsically Safe and Non-Incendive Systems - For Hazardous Locations

- NI, Class I, Division 2, Groups A, B, C and D, with IS circuits extending into Division 1; Enclosure 4X; or  
AIS, Class I, Zone 1, Ex me ib [ia] IIC T4; Enclosure 4X;  
or  
NI, Class I, Zone 2, Ex nA [ia] IIC; Enclosure 4X;  
Ambient temperature -20C...+50C

**Certificate:** 1662790

**Master Contract:** 220331

**Project:** 1752689

**Date:** January 18, 2006

The Protos Measuring System consists of the following units:

Model Code:	Description:
M 700X S/VPW	VariPower 100-230 Vac power supply, enclosure made of polished stainless steel
M 700X S/24B	24 Vac/dc power supply, polished stainless steel enclosure
M 700X C/VPW	VariPower 100-230 Vac power supply, enclosure made of polyester coated steel
M 700X C/24V	24 Vac/dc power supply, enclosure made of polyester coated steel

Door Type	
Model Code:	Description:
FRONT 700 XS-015	Door, made of polished stainless steel
FRONT 700 XC-015	Door, made of coated steel

Module Type	
Model Code:	Description:
PH 2700 X	pH measurement with glass electrodes or ISFET sensors

Module Type	
Model Code:	Description:
Cond 7700 X	conductivity measurement with 2 and 4 electrodes / sensors
Cond Ind 7700 X	inductive conductivity measurement with 2 and 4 electrodes sensors

Module Type	
Model Code:	Description:
O2 4700 X	oxygen measurement in liquids, standard application
O2 4700 X ppb	oxygen measurement in liquids, trace measurements

Module Type	
Model Code:	Description:
EC 700 X	pH measurement with glass electrodes, supply and control of retractable probe
control unit Type Unical	9000-X***

Module Type	
Model Code:	Description:
Out 700 X	output module, provides analog and switch outputs

Module Type	
Model Code:	Description:
PID 700 X	PID controller

Module Type	
Model Code:	Description:
PA 700 X	Interface for Profibus-PA (MPB-IS)
FF 700 X	Interface for Foundation Fieldbus (FF-H1)

The Protos Measuring System consists of the following units:



**Certificate:** 1662790

**Master Contract:** 220331

**Project:** 1752689

**Date:** January 18, 2006

---

The Protos Measuring System consists of the following units:

Model Code:	Description:
pH 2700i X	pH measurement with pH glass electrodes or pH-ISFET sensors
CO2 5700i X	Carbon dioxide measurement
O2 4700i X	oxygen measurement in liquids, standard application
O2 4700i X ppb	oxygen measurement in liquids, trace measurements

### **MARKINGS**

Markings are done on CSA accepted type labels as per drawings 230.040-130 and 230.040-140.

Listee's name and/or CSA file number 220331, model designation, complete electrical rating in volts, hertz, hp, amps, serial number or date coding, and the CSA Mark appear in a permanent manner on each unit.



GSA INTERNATIONAL

## Supplement to Certificate of Compliance

Certificate: 1662790

Master Contract: 220331

*The products listed, including the latest revision described below,  
are eligible to be marked in accordance with the referenced Certificate.*

### Product Certification History

Project	Date	Description
1805798	June 21, 2006	<u>Submittor Models:</u> PH 3400 X-035 CO2 3400 X-130 OXY 3400 X-065 OXY 3400 X-066
		<u>Listee Models:</u> Ph 2700i X CO2 5700i X O2 4700i X O2 4700i X ppb
1752689	January 18, 2006	<u>Submittor Models:</u> BASE 3400 XS/VPW BASE 3400 XS/24V BASE 3400 XC/VPW BASE 3400 XC/24V  FRONT 3400 XS-015 FRONT 3400 XC-015  PH 3400 X-032  COND 3400 X-041 CONDI 3400 X-051  OXY 3400 X-062 OXY 3400 X-063  OUT 3400 X-071  PID 3400 X-121  COMPA 3400 X-081 COMFF 3400 X-085 PHU 3400 X-110
		<u>Listee Models:</u> M 700X S/VPW M 700X S/24V M 700X C/VPW M 700X C/24V  FRONT 700 XS-015 FRONT 700 XC-015  pH 2700 x  Cond 7700 X Cond Ind 7700 X  O2 4700 X O2 4700 X ppb  Out 700 X  PID 700 X  PA 700 X FF 700 X EC 700 X

**MASTER CONTRACT:** 220331

**REPORT:** 1662790

**PROJECT:** 1662790

**Page No:** 2

**Date Issued:** May 10, 2005

1662790

May 18, 2005

Original Report No	Model No.	Listee Model No.
188909-1606678	22*1X pH	2100/2XH
	22*1X Cond	7100/2XH
	22**X Condl	7100/2XH
	221*X Oxy	4100/2XH